

- c. Out of the fifty (50) participants who will attend the training for SCBA and SCBA Refilling System, only twenty-five (25) personnel shall attend the CERTIFIED TECHNICIAN TRAINING for both equipment; and
- d. For conformity purposes, all participants shall receive complete, organized and presentable training manuals both in CD and hard copy duly bound with durable binding materials. An addition seven (7) sets shall also be provided for BFP COA, COA-TSO, OAF, ODCO, ODO, ODPSD, and ODL based on the latest instructions/requests from these offices.

6. The clock in the BFP GAD Library bearing the picture of the current Chairman of the BFP BAC shall be the official time of the NHQ BAC.

B. CHECKLIST OF REQUIREMENTS

1. Bidders shall include in the list (both forms, SF-GOODS-13a and SF-GOODS 13b) all its ongoing government and private contracts including contracts awarded but not yet started as well all its previous completed contracts which are similar in nature. For SF-GOOD 13b, however, the bidder may just submit/attached one single completed contract that is similar to the contract to be bid equivalent to at least (50%) of the ABC.

2. For 2nd requirement under Class "A" Technical Documents of the Checklist – Copies of end-user's acceptance letters for completed contracts -- Delivery Receipt or other proof of acceptance will suffice the requirement.

C. BID DATA SHEET

1. On Section 13.2 (a.5) on Income and Business Tax Return, to read as:

"Other appropriate licenses ... latest Tax Clearance, Income Tax Returns of the preceding year, 2008, electronically filed with the BIR; Business Tax Returns for CY 2009 (2550M – consisting of January, February, April & May and 2550Q – March and June, all of CY 2009); ..."

2. Section 23.2 on, to read as:

"Each Bidder shall submit one (1) original/authenticated copy and two (2) photocopies of each Eligibility Documents, Technical and Financial Proposals"

D. TECHNICAL REQUIREMENTS

Item II. B.1 (Power Supply) Page 1, the word power supply will be deleted and shall be changed to Engine Drive and shall be read as:

"1. Engine Drive: Diesel driven engine of sufficient rating."

Item II. C (Control Panels and Standard Features), Page 2, a new standard feature shall be inserted as item no. 7 and the former item no. 7 shall be move as item no. 8 and shall be read as:

"7. Automatic Filter Cartridge Saturation Control System equipped with audio-visual warning/indicator and shut down device."

"8. Automatic Control and Display/Indicator Panel"

Item II.D.1 (Tank Filling Assembly) Page 2, which states that "1. Switch over device (200 bar/3000 psig to 300 bar/4500 psig)" shall be completely changed and read as:

"1. Factory pre-adjusted/set pressure reducing/ maintaining device(s) to allow simultaneous filling of the 300 bar/4500 psig and 200 bar/3000 psig SCBA cylinder tanks"

Item II.D.2 (Tank Filling Assembly) Page 2. shall have the following corrections and revisions and shall be read as: